

Sixth Floor, 900 Howe Street Vancouver, BC Canada V6Z 2N3 TEL: (604) 660-4700 BC Toll Free: 1-800-663-1385 FAX: (604) 660-1102

ORDER NUMBER R-18-16

IN THE MATTER OF the Utilities Commission Act, RSBC 1996, Chapter 473

and

Tolko Industries Limited Application for Dismissal of a Confirmed Violation of Mandatory Reliability Standards: PRC-011-0 Requirement 1 - Violation ID: BCUC2013000489 PRC-011-0 Requirement 2 - Violation ID: BCUC2013000490

BEFORE:

D. M. Morton, CommissionerD. J. Enns, CommissionerH. G. Harowitz, CommissionerR. I. Mason, Commissioner

on May 19, 2016

ORDER

WHEREAS:

A. By email notification dated May 12, 2016, the Western Electricity Coordinating Council (WECC) recommended dismissal of the following Confirmed Violations for Tolko Industries Limited (Tolko):

Confirmed Violation	BCUC Violation ID	Commission Order Confirming Alleged Violation	Date of Commission Order	Date of WECC Recommendation of Dismissal
PRC-011-0 R1	BCUC2013000489	R-16-14	May 22, 2014	May 12, 2016
PRC-011-0 R2	BCUC2013000490	R-16-14	May 22, 2014	May 12, 2016

- B. Order G-123-09 approved the Compliance Monitoring Program (CMP), which provides a process for dealing with violations of Mandatory Reliability Standards (MRS) adopted by the British Columbia Utilities Commission (Commission) and Order R-34-15 approved revisions and updates to the CMP;
- C. On April 14, 2014, WECC, acting as the Commission's MRS Administrator, issued a Notice of Alleged Violation (NOAV) to Tolko for the alleged violations of the reliability standards noted above. Tolko chose not to submit a formal response to the NOAV and instead informed WECC and the Commission that it was preparing Mitigation Plans for the Alleged Violations;

- D. By Commission Order R-16-14, dated May 22, 2014, the Commission confirmed the Alleged Violations noted above;
- E. During a subsequent review of Tolko's Undervoltage Load Shedding (UVLS) equipment, WECC assessed that the purpose of Tolko's UVLS equipment is solely to provide protection for Tolko's own system infrastructure and equipment by taking it offline during an undervoltage event. As such, the UVLS equipment is not applicable to a UVLS program as described in reliability standard PRC-011-0; and
- F. The Commission reviewed WECC's recommendation and considers dismissing the Confirmed Violations and rescinding Order R-16-14 is warranted.

NOW THEREFORE pursuant to section 125.2(10) of the *Utilities Commission Act* and in accordance with the Compliance Monitoring Program, the British Columbia Utilities Commission dismisses the Confirmed Violations identified above and rescinds Commission Order R-16-14.

DATED at the City of Vancouver, in the Province of British Columbia, this 19th day of May 2016.

BY ORDER

Original signed by:

D. M. Morton Commissioner